

TO WHOM IT MAY CONCERN:


The CAFCO® products listed below, manufactured by United States Mineral Products Company dba Isolatek International were analyzed for fibrous asbestos content by an independent testing laboratory. Product samples were randomly selected and sent to the RJ Lee Group, Inc. for analysis. The RJ Lee Group is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP, #101208-00) for asbestos fiber analysis.

The samples were analyzed for asbestos content using polarized light microscopy (PLM) following the methodology EPA/600/R-93/116, *Method for Determination of Asbestos in Bulk Building Materials*. Each sample was also analyzed using transmission electron microscopy (TEM) in accordance with the analytical portion of ASTM d-5756, *Standard Test Method for Microscopy for Asbestos Mass Surface Loading*.


The test results are reported below:

PRODUCT NAME	ASBESTOS CONTENT
CAFECO 300	None Detected
CAFECO 400	None Detected
CAFECO BLAZE-SHIELD®II	None Detected
CAFECO BLAZE-SHIELD HP	None Detected
CAFECO FENDOLITE®M-II	None Detected

ISOLATEK INTERNATIONAL


GIOVANNI C. PACHECO
Chief Executive Officer

Sworn and subscribed to before me
this 25th day of November, 2008.


Notary Public

KATHLEEN M. STUDENY
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires Aug. 1, 2011



Total Passive
Fire Protection

41 Furnace Street • Stanhope • New Jersey 07874
Tel 973.347.1200 • Fax 973.347.9170 • E-Mail cafco@isolatek.com

www.cafco.com